



NOTES:

- 1.) CONCRETE SHALL BE CLASS 560-C-3250 P.C.C., CURED WITH WHITE PIGMENTED CURING COMPOUND.
- 2.) THE SURFACE OF ALL EXPOSED CONCRETE SHALL CONFORM IN SLOPE, GRADE, FINISH, AND SCORING TO EXISTING CURB, GUTTER AND WALK ADJACENT TO THE STRUCTURE.
- 3.) CURVATURE OF CONCRETE SURFACE SHALL BE SHAPED BY CURVED FORMS AND SHALL NOT BE SHAPED BY PLASTERING.
- 4.) THE INVERT OF THE STRUCTURE SHALL BE GIVEN A STEEL TROVELED FINISH AND CONSTRUCTED ON A STRAIGHT GRADE FROM THE INLET INVERT THROUGH POINT B TO POINT A.
- 5.) DIMENSIONS (UNLESS OTHERWISE INDICATED ON THE PROJECT PLANS):
AB = 5'
BC = 3'
DE = 5'
W = 3'
- 6.) DOWELS SHALL BE REQUIRED AT EACH CORNER AND AT 2 FEET O.C. (MAX.) WHEN THE TOP SLAB IS CONSTRUCTED SEPARATELY. WHEN THE TOP SLAB IS CONSTRUCTED MONOLITHIC WITH ADJACENT SIDEWALK, THE DOWELS MAY BE OMITTED.
- 7.) INSTALL FACE ANGLE AND ANCHORS AT THE OUTLET OF THE STRUCTURE IN CONFORMANCE WITH STANDARD PLAN NO. 300C.
- 8.) INSTALL CATCH BASIN MANHOLE FRAME AND COVER CONFORMING TO A.P.W.A. STANDARD PLAN NO. 312-0. AGENCY INSCRIPTION SHALL BE "MORENO VALLEY".

CAPITAL PROJECTS		DATE	1/05	CITY OF MORENO VALLEY PREPARED BY CAPITAL PROJECTS		
APPROVED BY		DIVISION MANAGER INITIAL				2 of 2
PUBLIC WORKS DIRECTOR/ CITY ENGINEER				SIDEWALK OUTLET STRUCTURE NOTES		NO. 301B