



NOTES:

- PLACE ONE 1" DIAM. SUPPORTING BOLT FOR EVERY 7' LENGTH OF CATCH BASIN OPENING, SPACED EVENLY OVER THE ENTIRE OPENING.
- WHERE SIDEWALK EXISTS ADJACENT TO CATCH BASIN, TOP SLAB SHALL BE EXTENDED TO JOIN SIDEWALK. TRANSVERSE STEEL IN TOP SLAB SHALL EXTEND 12" BEYOND WALK.
- SEE STANDARD #305 & 305A FOR DETAIL OF CATCH BASIN INLET AND DEPRESSION.
- BACKFILL MATERIAL TO SUBGRADE SHALL BE SAND, PLACED A MINIMUM OF 2' Laterally around structure.

DATE OF REVISIONS	NATURE OF	CITY OF SANTA ANA IMPROVEMENT STANDARD		STD. NO. 203
8-72	REW COVER AND ARMOR CHNG.	CATCH BASIN TYPE "B"		
7-74	REW BACKFILL NOTE			
10-74	REW REV. W	APPROVED: <i>P. E. Wolford</i>	CITY ENGINEER	DATE 10/22/65