



**NOTES:**

1. FOR CATHODIC TEST STATION AT MANHOLE, SEE STD DWG 904.
2. PROVIDE WEEPHOLES WHERE WATER TABLE IS BELOW BOTTOM OF PIPE & AS DIRECTED BY OWNER, DO NOT WATERPROOF IF WEEPHOLES ARE PROVIDED.
3. WATERPROOF OUTSIDE MANHOLE STRUCTURE WITH CRYSTALLINE AS MANUFACTURED BY PERMAQUIK OR APPROV. EQUIV.
4. 6" MINIMUM DISTANCE FROM TOP OF PIPE OR CROTCH PLATE (SINGLE OR DOUBLE) TO TOP OF CONCRETE BASE.

REVISION	DATE	BY	DESCRIPTION	CALLEGUAS MUNICIPAL WATER DISTRICT	STANDARD DRAWINGS MANHOLE ACCESS STRUCTURE	DWG NO 711A
6	03/06	P&I	GENERAL			
7	11/06	P&I	GENERAL			
8	12/06	P&I	GENERAL	THOUSAND OAKS	CALIFORNIA	
APPROVED <b>Susan Mulligan</b> MANAGER OF ENGINEERING				Digitally signed by Susan Mulligan DN: cn=Susan Mulligan, c=US Date: 2006.12.11 10:07:22 -0800		