



NOTE: PIPE SIZE AND OUTLET TO BE SHOWN ON GENERAL PLANS. STANDARD CATCH BASIN TO BE 4'-0" X 3'-0" INSIDE UNLESS OTHERWISE SHOWN ON GENERAL PLANS. CONSTRUCT 1/2" PER FOOT SLOPE ON BOTTOM OF CATCH BASIN TOWARD OUTLET. THE AMOUNT AND LENGTH OF STEEL USED IN CONSTRUCTION TO VARY ACCORDING TO THE SIZE OF THE CATCH BASIN.

APPROVED <i>Robert C. Walsh</i> DATE <i>8/3/98</i>		PUBLIC WORKS DIRECTOR - R.C.E. 18793	
①	Added Station Line	<i>WJG</i>	<i>8-25-80</i>
②	Changed Sq. Manhole to Round	<i>WJG</i>	<i>7-7-82</i>
③	REMOVED LOCKING REQ'M	<i>TJB</i>	<i>4/21/04</i>
MARK	REVISIONS	APPR.	DATE

CITY OF RIVERSIDE
PUBLIC WORKS DEPT. - ENGINEERING DIV.
STORM WATER CATCH BASIN
TYPE 1

STANDARD DRAWING NO. 400