



**NOTES:**

1. Concrete shall have a minimum ultimate compressive strength at 28 days of 2500 p.s.i. Concrete may be pneumatically placed and shall conform to Section 1924 of the Uniform Building Code.
2. Reinforcing shall be 6" x 6"-W1.4 x W1.4 welded wire mesh (W.W.M.) or approved equal.
3. Ground shall be pre-wetted to the satisfaction of the Building Official or Engineer prior to placement of concrete. Curing compound shall be used when required by the Building Official or Engineer.
4. Anchors shall be constructed in accordance with Standard Plan 1321 (Sheet 2) when slope equals or exceeds 2:1.

ORANGE COUNTY RESOURCES & DEVELOPMENT MANAGEMENT DEPARTMENT

Approved

*H. I. Nakasone*  
H. I. Nakasone, Chief Engineer

Adopted: Res. 82-718

Revised: Res. 06-010

STD. PLAN

1332

INTERCEPTOR DRAIN

SHT. 1 OF 1