

**NOTES:**

DRAFT

1. ALL CURVED CONCRETE SURFACES SHALL BE FORMED BY CURVED FORMS AND SHALL NOT BE SHAPED BY PLASTERING.
2. TWO GRATINGS ARE REQUIRED UNLESS OTHERWISE SHOWN ON THE PROJECT PLANS.
3. FLOOR OF BASIN SHALL BE GIVEN A STEEL TROWEL FINISH AND SHALL HAVE A LONGITUDINAL AND LATERAL SLOPE OF 1:12 MINIMUM AND 1:3 MAXIMUM, SLOPE FLOOR FROM ALL DIRECTIONS TO THE OUTLET.
4. DIMENSIONS:  
 $V = 3.5$  FEET  
 $V_1 =$  THE DEPTH AT THE INVERT OF THE INLET. NOTED ON THE PROJECT PLANS.  
 $W = 4$  FEET  $3\frac{1}{2}$  INCHES FOR TWO GRATINGS; ADD 2 FEET 2 INCHES FOR EACH ADDITIONAL GRATING.  
 $A =$  THE ANGLE, IN DEGREES, INTERCEPTED BY THE CENTERLINE OF THE CONNECTOR PIPE AND THE CATCH BASIN WALL TO WHICH THE CONNECTOR PIPE IS ATTACHED.
5. PLACE CONNECTOR PIPES AS INDICATED ON THE PROJECT PLANS UNLESS OTHERWISE SPECIFIED, THE CONNECTOR PIPE SHALL BE LOCATED AT THE DOWNSTREAM END OF THE BASIN WHERE THE CONNECTOR PIPE IS SHOWN AT A CORNER, THE CENTERLINE OF THE PIPE SHALL INTERSECT THE INSIDE CORNER OF THE BASIN. THE PIPE MAY BE CUT AND TRIMMED AT A SKEW NECESSARY TO INSURE MINIMUM 3-INCH PIPE EMBEDMENT, ALL AROUND, WITHIN THE CATCH BASIN WALL, AND 3-INCH RADIUS OF ROUNDING OF STRUCTURE CONCRETE, ALL AROUND, ADJACENT TO PIPE ENDS. A MONOLITHIC CATCH BASIN CONNECTION SHALL BE USED TO JOIN THE CONNECTOR PIPE TO THE CATCH BASIN WHENEVER ANGLE "A" IS LESS THAN 70 DEGREES OR GREATER THAN 110 DEGREES, OR WHENEVER THE CONNECTOR PIPE IS LOCATED IN A CORNER. THE OPTIONAL USE OF MONOLITHIC CATCH BASIN CONNECTION IN ANY CASE IS PERMITTED. MONOLITHIC CATCH BASIN CONNECTIONS MAY BE CONSTRUCTED TO AVOID CUTTING STANDARD LENGTHS OF PIPE.
6. STEPS SHALL BE LOCATED AS SHOWN. IF THE CONNECTOR PIPE INTERFERES WITH THE STEPS, THEY SHALL BE LOCATED ON THE OPPOSITE WALL. STEPS SHALL BE SPACED 12 INCHES APART. THE TOP STEP SHALL BE 7 INCHES BELOW THE TOP OF THE GRATING AND PROJECT  $2\frac{1}{2}$  INCHES. ALL OTHER STEPS SHALL PROJECT 5 INCHES.
7. CONCRETE SHALL BE CLASS 560-C-3250 WITH A MAXIMUM SLUMP OF 5",  $FC' = 3250$  P.S.I. COMPRESSIVE STRENGTH AT 28 DAYS, UNLESS OTHERWISE NOTED ON THE CONTRACT PLANS, REINFORCING STEEL IF REQUIRED SHALL BE DEFORMED REBARS WITH  $F_y$  EXCEEDING 60,000 PSI, ASTM A615 AND ASTM A706, GRADE 60. PLACING OF REINFORCEMENT AND SPLICING LENGTHS SHALL CONFORM TO ACI CODES 318-13.
8. THE FOLLOWING STANDARD PLANS ARE INCORPORATED HEREIN:  
 D-10 MONOLITHIC CATCH BASIN CONNECTION  
 D-11 CATCH BASIN REINFORCEMENT  
 D-13 FRAME AND GRATING FOR CATCH BASINS  
 D-16 STEEL STEP

**THE PORT OF LONG BEACH** ENGINEERING DIVISION

REVISIONS		<div style="font-size: 1.5em; font-weight: bold;">CATCH BASIN NO. 6</div> <div style="font-size: 1.2em; font-weight: bold;">TRANSVERSE GRATING TYPE</div>	STANDARD PLAN
NO.	DATE		D-6
①			
②			
③			
APPROVED BY: _____		R.E. NO.: _____	DATE: _____
CHIEF HARBOR ENGINEER			2 OF 2