



- NOTES:
1. MANHOLE RINGS, CONES AND SECTIONS SHALL BE APPROVED BY CITY.
 2. MORTAR SHALL BE 1 PART CEMENT TO 4 PARTS SAND.
 3. MANHOLES WITH A DEPTH GREATER THAN 10 FEET SHALL BE 60" DIAMETER STANDARD MANHOLES. PROVIDE ENGINEERED DETAIL.



Approved By
City Administrator
R. Puceri
Date
5-3-91

Approved By
City Engineer
A. Boyd
Date
5/2/91

48" I.D. STANDARD MANHOLE			Standard Detail No.
1	9/6/08	CB	S-1
No.	Date	App.	Revision