



- NOTES:
1. PARKWAY CULVERT SHALL BE CONSTRUCTED OF CLASS "3" CONCRETE WHICH SHALL ATTAIN A 28-DAY COMPRESSIVE STRENGTH OF 4000 PSI IN ACCORDANCE WITH ASTM C39/C39M-99.
 2. ALL STEEL EXCEPT REINFORCING BARS SHALL BE GALVANIZED AFTER FABRICATION.

APPROVED: PUBLIC WORKS DIRECTOR
James W. Rodkey, Jr. DATE 9/7/00
 JAMES W. RODKEY, JR.
 APPROVED: CITY ENGINEER
Robert K. Holt DATE 8/31/00
 ROBERT K. HOLT, P.E.

CITY OF
BLYTHE

PARKWAY CULVERT
 W/STEEL PLATE COVER

REVISION	BY	DATE