



NOTES:

- 1) INSTALL ROUND NON-TRAFFIC TYPE CONCRETE VALVE BOX & COVER MARKED "SEWER" IN A NON - TRAFFIC AREA . INSTALL METAL LID MARKED "SEWER" IN AREAS WITH POTENTIAL TRAFFIC. A G5 BOX SHALL BE INSTALLED IN TRAFFIC AREAS.
- 2) THREE FOOT VCP STUB SHALL BE INSTALLED UPSTREAM OF CLEANOUT.
- 3) CLEANOUT BOX TO BE FREE OF ALL DIRT AND READY AT TIME OF PRE-FINAL INSPECTION.
- 4) SERVICES OVER 100' LONG AND COMMERCIAL SERVICES REQUIRE A MIN. 6" CLEANOUT WITH 6" FITTINGS. THE CLEANOUT BOX SHALL BE CONSTRUCTED PER W-16.
- 5) CONNECTION TO MAIN SHALL BE WITH A FACTORY WYE OR AT A MANHOLE.
- 6) THE CLEANOUT RISER SHALL BE INSTALLED 12" ABOVE GRADE PRIOR TO BUILDING CONSTRUCTION.
- 7) BUILDING CONTRACTOR SHALL SET BOX TO FINISH GRADE AND INSTALL AN ABS PLUG SET 6" BELOW THE SURFACE PRIOR TO BUILDING PRE-FINAL.
- \* 8) BACKWATER VALVE IF REQUIRED SHALL BE INSTALLED BY THE BUILDING CONTRACTOR

DERRICK WHITEHEAD  
ENVIRONMENTAL UTILITIES DIRECTOR



ENVIRONMENTAL UTILITIES  
DEPARTMENT

SEWER SERVICE CLEANOUT

SCALE: NONE  
REVISED: MARCH 2007  
DRAWN BY: R. VAN NESS  
APPROVED BY: D. WHITEHEAD

SS-5