



- | ITEM | MATERIALS |
|------|--|
| 1 | 6" CLEAN-OUT RISER, SEE NOTE 1. |
| 2 | PLUG END WITH RUBBER STOPPER. |
| 3 | (MAIN SIZE)X 6" WYE BRANCH FITTING. |
| 4 | CLASS "B" CONCRETE COLLAR (ROUND). |
| 5 | CLASS "B" CONCRETE COLLAR (SQUARE). |
| 6 | PIPE STUB, 24" LONG. |
| 7 | CONSTRUCT FRAME, COVER AND CONCRETE COLLAR PER "PAVED" OR "UNPAVED" CONDITION HEREON. |
| 8 | PRECAST BOX, FRAME AND COVER WITH MARKING AS SHOWN HEREON. COVER TO HAVE FOUR 3/4" DIAMETER HOLES. |
| 9 | 45° BEND, LONG-RADIUS SWEEP. SEE NOTE 2. |
| 10 | STAINLESS STEEL BANDED, RUBBER COUPLING. |
| 11 | ABS RUBBER STOPPER. |

NOTES:

- CLEANOUT RISER PIPE TO BE 6" DIAMETER AND SAME KIND OF MATERIAL AS SEWER MAIN.
- ANGLE OF BEND MAY CHANGE TO ACCOMMODATE STEEP PIPE SLOPES.

ELEVATION

TERMINAL CLEANOUT

REVISION			
NO.	DATE	APPROVED	DATE

STANDARD SPECIFICATIONS COMMITTEE		
J STANEART		8/31/04
CHAIRMAN		DATE
ENGINEERING DEPT.		
[Signature]		8/31/04
DIRECTOR OF ENGINEERING		DATE



IRWD
STD.DWG.
S-5
SHEET 1 OF 1