


1 COVER REQUIRED

CASE 1: 3' \times 18" (900 mm \times 450 mm) TREE WELL CASE 2: 4' \times 24" (1200 mm \times 600 mm) TREE WELL




2 COVERS REQUIRED

CASE 3: 3' \times 3' (900 mm \times 900 mm) TREE WELL CASE 4: 4' \times 4' (1200 mm \times 1200 mm) TREE WELL

TREE WELLS

CASE	Α	В	С	D	E	R
1	3'-0"	18"	2'-11"	17 1/2"	5'-0"	9"
	(900 mm)	(450 mm)	(975 mm)	(450 mm)	(1500 mm) MIN	(225 mm)
2	4'-0"	(24")	3'-11"	23 1/2"	5'-6"	15"
	(1200 mm)	(600 mm)	(1175 mm)	(600 mm)	(1650 mm) MIN	(375 mm)
3	3'-0"	3'-0"	2'-11"	17 1/2"	6'-6"	9"
	(900 mm)	(900 mm)	(975 mm)	(450 mm)	(1950 mm) MIN	(225 mm)
4	4"-0"	4'-0"	3'-11"	23 1/2"	7'-6"	15"
	(1200 mm)	(1200 mm)	(1175 mm)	(600 mm)	(2250 mm) MIN	(375 mm)



POROUS TREE WELL COVER (SEE NOTE 2)

NOTES FOR TYPE 3 TREE WELL

- SEE SHEET 7 FOR NOTES PERTAINING TO THE SHEET.
- 2. PERMEABLE (POROUS) CONCRETE TREE WELL COVER:

 THE COVER SHALL BE MADE OF PERMEABLE CONCRETE WITH A

 MINIMUM COMPRESSIVE STRENGTH OF 1200 PSI (8.5 MPa) AND SHALL BE
 PRECAST & REINFORCED WITH 2 1/4" X 2 1/4" (60 mm x 60 mm) 16 GAUGE
 WIRE MESH. CONCRETE SHALL CONSIST OF ONE PART CEMENT TO
 FOUR PARTS 3/8" (10 mm) GRAVEL AND APPROXIMATELY FOUR GALLONS
 (15 LITERS) OF WATER PER SACK OF CEMENT. THE GRAVEL SHALL BE
 CLEAN WITH FINES REMOVED. CURING COMPOUND TO WHICH WATER—
 PROOFING MATERIALS HAVE BEEN ADDED WILL NOT BE PERMITTED.

TYPE 3

STANDARD PLANS FOR PUBLIC WORKS CONSTRUCTION

TREE WELL

SHEET 4 OF 7