



NOTES:

1. CLEANOUT TO GRADE TO BE PVC OR ABS (ASTM D2661) WITH SOLVENT WELD JOINTS.
2. FOR 4" SERVICES IN NON-TRAVEL WAYS, INSTALL ROUND NON-TRAFFIC TYPE CONCRETE OR PVC VALVE BOX AND COVER MARKED "SEWER". BOX INSIDE DIAMETER TO BE A MINIMUM OF 7" AND A MAXIMUM OF 10".
3. FOR SERVICES 4" AND 6" OR LARGER IN CONCRETE OR TRAVEL WAYS, INSTALL ROUND CONCRETE TRAFFIC TYPE VALVE BOX WITH CAST IRON COVER. COVER TO BE MARKED "SEWER".
4. IF A WATER MAIN IS TO BE INSTALLED AT THE BACK OF SIDEWALK, EXTEND SERVICE TO THE BACK OF THE 12.5' P.U.E. BACK OF SIDEWALK; CLEANOUT TO GRADE TO REMAIN 1' TO 3' FROM BACK OF SIDEWALK AND A SECOND CLEANOUT TO BE INSTALLED ON THE END OF THE EXTENSION 12.5' BACK OF SIDEWALK. SEE STANDARD DRAWING 7-4C-13A.
5. VCP SHALL BE BELL & SPIGOT WITH POLYURETHANE JOINT.

PLACE A MINIMUM OF 12" OF BACKFILL ALL AROUND THE OUTSIDE DIAMETER OF THE RISER AND MECHANICALLY COMPACTED TO 90% RELATIVE DENSITY. BACKFILL MATERIAL SHALL BE USED TO 12" FROM GRADE OR TO TOP OF SUBGRADE IF UNDER CONCRETE.

**SACRAMENTO COUNTY
MUNICIPAL SERVICES AGENCY**

**VCP, ABS
CLEANOUT TO GRADE**

DRAWN BY: RAS
SCALE: NONE
DATE: 11/07

7-4C-14A

Mary K Snyder
DIRECTOR