

SPECIFICATIONS

1. Precast M.H. sections shall conform to applicable provisions of ASTM C-478.
2. Steps shall be galvanized steel, 3/4" dia, plastic coated, and inserted 3" min.
3. For use with pipe less than 24" in diameter and less than 4 feet of cover.


U-shaped channel may be formed in M.H. base or constructed by laying pipe through the M.H. and breaking out top half of the pipe and forming remainder of U-shaped channel in concrete.

Rev	By	Date
0	DWH	12/14/92
1	JT	07/31/06

Scale: NTS

**Storm Manhole for
Shallow Pipe Locations
(36" Cover or Less)**

City of Palo Alto Standard

Approved by:

 PE No. 35411
 Date 5/14/07
 Dwg No. 314