



**NOTES:**

1. CONCRETE SHALL BE 560-C-3250.
2. D = INSIDE DIAMETER OF PIPE OR DEPTH OF CHANNEL.
3. SECTION TO BE SLOPED LATERALLY WITH TOP CONFORMING TO THE GRADES OF THE EXISTING SIDEWALK AND CURB.
4. MANHOLE FRAME AND COVER MAY BE DELETED WITH OPEN CHANNEL.
5. TROWEL FINISH TOP SURFACE AND REPRODUCE MARKINGS OF EXISTING SIDEWALK AND CURB.
6. TROWEL FINISH FLOOR OF OUTLET.
7. ELEVATION OF TOP OF CURB PER CURB GRADE LINE, LOWER FLOW LINE IF OPENING IS GREATER THAN 4".
8. SEE STD. 220-2.5 FOR TRANSITION TO DOWN DRAIN OR OPEN CHANNEL

Revised	Drawn <i>Sila</i>	Date	<b>CITY OF CORONA PUBLIC WORKS DEPARTMENT</b>	<b>PARKWAY</b>	<b>UNDERDRAIN</b>	<b>STD. PLAN</b>
11/88	Approved	Date 3-3-86				
9/90	<i>Joseph R. Palencia</i> Director of Public Works		<b>107-0</b>			