


NOTES:

1. PLACE TWO HALF MOON SHAPED PLYWOOD COVERS (5/8" THICK MINIMUM) IN BOTTOM OF MANHOLE AFTER SHAFTS HAVE BEEN SET TO KEEP DEBRIS FROM ENTERING SEWER.
2. FOR DROP MANHOLE SEE YVWD STD. DWG. S-12.
3. FOR MANHOLES LOCATED OUTSIDE PAVED AREAS THE FRAME AND COVER SHOULD BE SET A MINIMUM OF 0.1 FT. ABOVE FINISH GRADE IN SHOULDER AREAS, UNPAVED ROADS OR LANDSCAPED AREAS, AND 18" IN UNFINISHED AREAS.
4. ALL INLETS AND OUTLETS SHALL BE SUPPORTED WITH CONCRETE SUPPORTS PRIOR TO POURING MANHOLE BASE.

YUCAIPA VALLEY WATER DISTRICT

MANHOLE DETAIL

REVISIONS		APPROVED	DRAWN	APPROVED BY ENGINEERING DEPARTMENT		YVWD	S-3
NO.	BY			DATE	CHECKED		
		Nov. 2, 2000			12/6/00		S-3
					12/6/00		
					12/6/00		
			NO SCALE	ADOPTED BY BOARD OF DIRECTORS		SHEET 1 OF 1	