



NOTES

1. Owner shall be responsible for cleaning and maintaining pipe.
2. Minimum cross-slope to be 1% for drain pipe.
3. Place 6 x 6 wire mesh full length 24" on each side of pipe.
4. Under sidewalk drains to be used only by approval of City Engineer where a storm drain does not exist or extension of an existing storm drain is impractical.

CITY OF PALMDALE...

Under Sidewalk Drains

Std. No.
D-2

Approved John M. Mendenhall
City Engineer

1-9-91
Date