


NOTES:

1. IF THE TOE OF SLOPE IS ALLOWED WITHIN THE R/W, INLET CASE I BEGINS AT THE TOE RATHER THAN THE R/W LINE.
2. FOR DRAIN SWALE (CASE III INLET), THE 2' EXTENSION BEYOND THE R/W LINE IS NOT REQUIRED WHEN BACK OF WALK IS 2' OR MORE FROM THE R/W LINE; HOWEVER, PIPE SHALL EXTEND TO R/W LINE.
3. TOP OF INLET STRUCTURE (CASE I AND II) TO BE FLUSH WITH ADJACENT SURFACE WHERE PRACTICABLE.
4. CONSTRUCT P.C.C. WALK WHEN SPECIFIED ON PLAN. THE CONTRACT PRICE PAID FOR P.C.C. WALK ITEM SHALL INCLUDE WALK CONSTRUCTED IN CONJUNCTION WITH PARKWAY CULVERT.
5. "N" EQUALS NUMBER OF PIPES (MAXIMUM OF THREE) AS SPECIFIED ON PLAN. PIPE MATERIAL SHALL BE CAST IRON, DUCTILE IRON OR STEEL.
6. INLET CASE TO BE SPECIFIED ON IMPROVEMENT OR GRADING PLAN.
7. ANGLE "A" EQUALS 0°, UNLESS OTHERWISE SPECIFIED.
8. TYPE, DIMENSIONS AND ELEVATIONS OF P.C.C. CURB AND GUTTER PER IMPROVEMENT PLAN.
9. UNLESS OTHERWISE STATED, FRAME AND GRATE FOR CASE II INLET SHALL BE ALHAMBRA FOUNDRY 14"x14" A-2012 (GALVANIZED), LONG BEACH IRON WORKS, INC. X-311B (GALVANIZED) OR EQUAL.
10. AT LOCATIONS OF LESS THAN 8 INCH CURB FACE, USE 6x6-10x10 GALVANIZED WIRE FABRIC. WIRE FABRIC TO EXTEND 8 INCHES BEYOND THE EDGE OF METAL PIPES.
11. ALL CONCRETE SHALL BE CLASS 'A'.

12/01/05				City of Santa Maria	
RICHARD G. SWEET R.C.E. 44,213 EXP. 6/30/07				Standard Drawing	
REVISIONS		BY	APP	DATE	DESCRIPTION: SIDEWALK DRAIN - PIPE; NOTES
DRAWN BY: A.P.W.A.		DATE DRAWN: 1992		SCALE: NONE	
				STANDARD NUMBER	DR-14
				SHEET 2 OF 2	