

NOTES:

- 1. SEE PLANS FOR VALUES OF DIMENSION D AND ELEVATION E.
- 2. PIPE AND FITTINGS, UNLESS OTHERWISE NOTED, SHALL BE OF THE SAME MATERIALS AS THE SEWER, UNLESS APPROVED ADAPTORS ARE USED, AND MAY BE ANY OF THE FOLLOWING:
 - A. VC PIPE
 - B. PE PIPE
 - C. ABS SOLID WALL PIPE
 - D. ABS COMPOSITE PIPE
 - E. PVC PLASTIC PIPE
- 3. PIPE AND FITTINGS SHALL BE BEDDED AND ENCASED IN PCC AS SHOWN. PCC SHALL BE CLASS 450-C-2000(265-C-14). JOIN AND ALIGN PIPE AND FITTINGS BEFORE PLACING CONCRETE. MAINTAIN ALIGNMENT WHILE PLACING AND ALLOWING PCC TO SET.
- 4. THE ACCESS FRAME, COVER AND CAP SHALL BE CAST IRON. THE FINGER HOLES MAY BE DRILLED OR BLOCKED OUT PRIOR TO CASTING. THEY SHALL NOT BE PUNCHED OUT.
- 5. THE CONTRACTOR MAY PLACE EITHER CIRCULAR OR SQUARE CONCRETE PIPE WALL SUPPORTS.

STANDARD PLANS FOR PUBLIC WORKS CONSTRUCTION

STANDARD PLAN

204-2

SHEET 2 OF 2