



NOTES:

1. Frame and cover shall be Alhambra Foundry A-1240 or equal approved by Engineer.
2. Set frame and cover flush with pavement grade.
3. Cleanout larger than 8-inch shall be provided subject to the approval of the Engineer.
5. All pipe and fittings shall be SDR-35 P.V.C. per ASTM 3034.

|          |      |                         |   |                 |
|----------|------|-------------------------|---|-----------------|
| REVISION | DATE | APPROVED                | CITY OF SANTA BARBARA - PUBLIC WORKS DEPARTMENT | STANDARD DETAIL |
|          |      | <i>Anthony J. David</i> | CLEANOUT  | 5-003.0-06      |
|          |      |                         |   |                 |
|          |      |                         |   |                 |