

NOTES:

1. GRATE AND FRAME SHALL BE GALVANIZED. SEE STANDARD OR SPECIFICATIONS OR SPECIAL PROVISIONS.
2. FOR "t" WALL THICKNESS SEE TABLE ON INLET PLAN.
3. REINFORCING STEEL SHALL BE #4 BARS AT 18 ± CENTERS PLACED 1 1/2" CLEAR TO INSIDE OF BOX UNLESS OTHERWISE SHOWN.
4. STEP-NONE REQUIRED WHERE "H" IS 3'-6" OR LESS. INSTALL ONE STEP 16" ABOVE FLOOR WHEN "H" IS MORE THAN 3'-6" AND LESS THAN 5'-0". WHERE "H" IS MORE THAN 5'-0", STEPS SHALL BE EVENLY SPACED AT 12" INTERVALS FROM 16" ABOVE FLOOR TO WITHIN 6" OF THE TOP OF THE BOX. PLACE STEPS IN WALL WITHOUT PIPE OPENINGS.
5. PIPE(S) CAN BE PLACED IN ANY WALL.
6. EXCEPT FOR INLETS USED AS JUNCTION BOXES, BASIN FLOOR SHALL HAVE A MINIMUM SLOPE OF 4:1 FROM ALL DIRECTIONS TOWARD OUTLET PIPE AND SHALL HAVE A WOODEN TROWEL FINISH.
7. ALTERNATE REINFORCED FLOOR AT THE OPTION OF THE CONTRACTOR.

CITY OF MURRIETA
DEPARTMENT OF DEVELOPMENT SERVICES

REVISIONS	
5/92	APPROVED

**MISCELLANEOUS CURB INLET
 DETAILS AND NOTES**

STD. NO.

407c