



Length of Curb Opening	No. of Anchors
3' or less	2
3'-6" to 6'-0"	3

FACE ANCHOR ANCHOR DETAIL

OUTLET DETAIL

SPAN S	B	STEEL SCHEDULE J-BARS			CURB HEIGHT
		Size	Spacing O-C	Length	
2'-0"	3"	#3	7"	2'-9"	9.75"
2'-6"	"	"	"	3'-3"	"
3'-0"	"	"	"	3'-9"	"
3'-6"	"	"	6"	4'-3"	"
4'-0"	"	"	5"	4'-9"	"
4'-6"	4"	"	6 1/2"	5'-3"	10.75"
5'-0"	"	"	5"	5'-9"	"
5'-6"	"	"	4"	6'-3"	"
6'-0"	"	"	3 1/2"	6'-9"	"

TABLE 1

GENERAL NOTES:

1. Floor of Parkway Culvert shall have a steel trowel finish.
2. All exposed metal shall be galvanized after fabrication.
3. Span "S" will be determined from the required hydraulic capacity and limited to the dimension in Table 1. (Max. Span = 6.0').
4. Reinforcing steel shall be 1" clear to inside of Culvert unless otherwise shown.



4-2-04  
DATE APPROVED  
*[Signature]*  
PUBLIC WORKS DIRECTOR/C.E.  
*[Signature]*  
ASSISTANT CITY ENGINEER

CITY OF ORANGE PUBLIC WORKS DEPARTMENT

PARKWAY CULVERT  
DETAILS AND NOTES

STANDARD  
PLAN No.  
312