

ADJUSTABLE GATE BOX AND LID (TO BE PROVIDED BY LONG BEACH WATER DEPARTMENT)

PROPOSED ASPHALT CONCRETE LIFT OR OVERLAY

VARIES

STEM DEPTH, VARIES

14 INCHES

POLYVINYL CHLORIDE PIPE, SCHEDULE 40

TRENCH BACKFILL SLURRY

GATE BOX TO BE ADJUSTED TO GRADE WITH ASPHALT CONCRETE LIFT

FINAL STREET GRADE

6 INCHES MINIMUM

EXISTING ASPHALT CONCRETE OR CONCRETE PAVEMENT AND BASE

3 INCHES MINIMUM

VARIES

2 x 4 x 12 INCHES REDWOOD BLOCKING

RECONSTRUCTED GATE BOX DETAIL

PROPOSED ASPHALT CONCRETE LIFT OR OVERLAY

VARIES

REMOVE AND REPLACE WITH ASPHALT CONCRETE PAVEMENT

GATE BOX TO BE ADJUSTED TO GRADE WITH ASPHALT CONCRETE LIFT

EXISTING ASPHALT CONCRETE OR CONCRETE PAVEMENT AND BASE

3 INCHES MINIMUM

EXISTING 8 INCH SLEEVE, MATERIAL VARIES

ADJUSTABLE GATE BOX DETAIL

LONG BEACH WATER DEPARTMENT

GATE BOX RECONSTRUCTION AND ADJUSTMENT

DESIGNED BY DAVIS

CHECKED BY MANABAT

DATE 5-15-87

SCALE NONE

SUPERSEDES DWG. NO.

A5-1234

DRAWN BY IDIAN

RECOMMENDED

BUREAU ENGINEER C.E. NO. 19113

APPROVED

GENERAL MANAGER C.E. NO. 16644

SHEET

1 OF 1

WDS-120