



SECTION A-A

NOTES:

1. GUIDERAIL SHALL BE MADE OF 316 STAINLESS STEEL AND SHALL BE SIZED PER PUMP MANUFACTURER WITH INTERMEDIATE SUPPORT.
2. MIN OPENING HATCH SHALL NOT INTERFERE WITH PUMP REMOVAL AND MAINTENANCE OPERATIONS.
3. PAD, STAINLESS STEEL ANCHOR BOLT ASSEMBLY, AND LOCATION SHALL BE DESIGNED PER MANUFACTURER REQUIREMENTS.
4. THICKNESS OF WET WELL FLOOR SHALL BE PER STRUCTURAL ENGINEER RECOMMENDATIONS.

*Mary K Snyder*  
DIRECTOR

SACRAMENTO COUNTY  
MUNICIPAL SERVICES AGENCY

CIRCULAR  
WET WELL

DRAWN BY: PL  
SCALE: NONE  
DATE: 11/07

7-6C-20