



NOTES:

- 1- WHERE H > 8', THICKNESS OF WALL SHALL BE 8" AND WALL SHALL BE RE-INFORCED WITH #4 @ 18" OC. BOTH WAYS.
- 2- STEPS - NONE REQUIRED WHERE "H" IS LESS THAN 30 INCHES, WHERE "H" > 30 INCHES INSTALL STEPS W/ LOWEST RUNG 12" ABOVE FLOOR & HIGHEST RUNG NOT MORE THAN 6" BELOW TOP OF INLET. DISTANCE BTWN. STEPS = 12" & LENGTH OF WALL.
- 3- WHEN SHOWN ON PROJECT PLANS PLACE A #6 PROTECTION BAR HORIZ. ACROSS LENGTH OF OPENING & BEND BACK 4" INTO INLET WALL, ON EACH SIDE.
- 4- CURB SUPPORTS SHALL BE EVEN SPACED & MINIMAL IN NO. SO MAX SPAN ON UNSUPPORTED CURB IS 7'.

LENGTH OF CURB OPENING	NO. OF ANCHORS
3'-6" OR LESS	1-0"
10'-0"	10'-0"
14'-0"	14'-0"
21'-0"	21'-0"

STORM DRAIN INLETS & DETAILS

DRAWN BY:
SHAREN HICKS
DATE: MAR. 83

DEPT. OF COMMUNITY DEVELOPMENT
CITY OF BARSTOW

DRAWING
D-3