



ELEVATION

ITEM	No. REQ'D.	DESCRIPTION	APPROVED MATERIAL LIST NO.
1	1	CAST IRON CLEAN-OUT FRAME AND COVER. COVER SHALL BE MARKED "SEWER".	SD-06

NOTE:

1. CLEANOUTS SHALL BE INSTALLED AT THE END OF THE SEWER MAIN IF WITHIN 200 FEET OF A MANHOLE.
2. LETTERING SHALL BE CAST IN COVER.

APPROVED <i>Dan K. Pehr</i> ASSISTANT GENERAL MANAGER/OPERATIONS	DATE <u>2/3/96</u> RCE NO. <u>36810</u>	DESERT WATER AGENCY PALM SPRINGS, CALIFORNIA
		SEWER CLEAN-OUT
		STANDARD DRAWING S106
REVISION	BY	DATE