

BOARD OF PUBLIC WORKS
MEMBERS

AURA GARCIA
PRESIDENT

M. TERESA VILLEGAS
VICE PRESIDENT

DR. MICHAEL R. DAVIS
PRESIDENT PRO TEMPORE

VAHID KHORSAND
COMMISSIONER

SUSANA REYES
COMMISSIONER

TJ KNIGHT
ACTING EXECUTIVE OFFICER

CITY OF LOS ANGELES

CALIFORNIA



KAREN BASS
MAYOR

DEPARTMENT OF
PUBLIC WORKS
BUREAU OF
ENGINEERING

TED ALLEN, PE
CITY ENGINEER

1149 S. BROADWAY, SUITE 700
LOS ANGELES, CA 90015-2213

<http://eng.lacity.org>

August 28, 2024

David Savant, West Regional Manager
EJ USA, Inc.
287 W. Orange Show Lane
San Bernadino, CA 92408

SUBJECT: 1st EXTENSION - RENEWAL OF EJ 311000LA (22" DIA., S-346-2) CAST IRON FRAME AND COVER BD002390

Dear Mr. Savant:

Approval of the above listed product, which are in general conformance with Standard Plan S-346-2 (with minor deviations), is renewed for Citywide Use in the public right of way for pedestrian traffic applications (excluding driveway). This approval is valid for two years until August 28, 2026. This is the first extension of three extensions maximum and the maximum total duration of the approval with extensions is eight years. The permittee shall provide new submittals at the end of eight years.

Prior to installation, contractor and designer shall submit additional plugs/rivet nuts/accessories to reduce the vent hole size for ADA compliance (ex. cover shall have no openings exceeding ½ inch) for DSIG's review and approval.

The City assumes no responsibility for any and all safety related issues in regard to the installation and use of this product. It is the responsibility of the installer to understand the appropriate use and limitations of this product and to address any and all safety concerns with the manufacturer. Further, it is the installer's responsibility to conform to all applicable industry and regulatory safety requirements.

Please be advised that you are required to report any changes in material or geometry of this product to the City immediately and to recertify this product before it expires. A permit is required for the installation as this product is subject to site and fabrication inspections per Subsection 2-11 and Section 4 of the Standard Specifications for Public Works Construction (SSPWC) as amended by the Brown Book.

Please contact Material Control Section of Bureau of Contract Administration at 213-485-5080 to arrange for fabrication inspection. Please also maintain a copy of this approval for your record and provide one to the Contractor or other users in the field. If you have any questions, please contact (Alan) Chiu Tam at chiu.tam@lacity.org.

Sincerely,

(Alan) Chiu Tam, S.E., LEED AP
Senior Structural Engineer
Wastewater Conveyance Engineering Division
Bureau of Engineering

c.c. Jerry Simpson-Harris, Bureau of Contract Admin.