



**NOTES**

1. Concrete shall be 332 kg/M<sup>3</sup> -C-22Mpa (560-C-3250)
2. D=inside diameter of pipe or depth of channel.
3. Section to be sloped laterally with top conforming to the grades of the existing sidewalk and curb.
4. Manhole frame and cover may be deleted with open channel.
5. Trowel finish top surface and reproduce markings of existing sidewalk and curb.
6. Trowel finish floor of outlet.

Revision	By	Approved	Date
ORIGINAL		Kercheval	12/75
Add Metric		T.Stanton	03/03
Reformatted		T.Stanton	04/06

**SAN DIEGO REGIONAL STANDARD DRAWING**

**CURB OUTLET - TYPE A**

RECOMMENDED BY THE SAN DIEGO REGIONAL STANDARDS COMMITTEE

*T. Stanton* 3/01/2003

Chairperson R.C.E. 19246 Date

**DRAWING NUMBER D-25**